



# 中国国家强制性产品认证证书

证书编号: 2009010309321647

## 委托人名称、地址

台安科技(无锡)有限公司  
无锡国家高新技术产业开发区65-C号地块

## 生产者(制造商)名称、地址

台安科技(无锡)有限公司  
无锡国家高新技术产业开发区65-C号地块

## 生产企业名称、地址

台安科技(无锡)有限公司  
无锡国家高新技术产业开发区65-C号地块

## 产品名称和系列、规格、型号

热过载继电器

RHL-80, RHN-80R Ue: AC690V Ie: 17~25A, 24.5~36A, 35~47A, 45~60A, 58~75A, 72~90A;  
脱扣级别: 10A; 2P, 3P; 辅助触头: AC-  
15: Ue/Ie: 120V/6A, 240V/3A, 380V/1.9A, 480V/1.5A, 500V/1.4A, 600V/1.2A; DC-  
13: Ue/Ie: 125V/0.55A, 250V/0.27A

## 产品标准和技术要求

GB 14048.4-2010

上述产品符合强制性产品认证实施规则  
CNCA-01C-011:2007的要求, 特发此证。

发证日期: 2012年05月09日      有效期至: 2017年05月09日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2009年01月16日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 0495357



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2009010309321647

## NAME AND ADDRESS OF THE APPLICANT

TAIAN Technology (Wuxi) Co., Ltd.  
Block 65-C, Wuxi National High-Technology Industry Development  
Zone, Wuxi, Jiangsu Province, P. R. China

## NAME AND ADDRESS OF THE MANUFACTURER

TAIAN Technology (Wuxi) Co., Ltd.  
Block 65-C, Wuxi National High-Technology Industry Development  
Zone, Wuxi, Jiangsu Province, P. R. China

## NAME AND ADDRESS OF THE FACTORY

TAIAN Technology (Wuxi) Co., Ltd.  
Block 65-C, Wuxi National High-Technology Industry Development  
Zone, Wuxi, Jiangsu Province, P. R. China

## NAME, MODEL AND SPECIFICATION

Thermal Overload Relay

RHU-80, RHN-80R Ue: AC690V Ie: 17~25A, 24.5~36A, 35~47A, 45~60A, 58~75A, 72~90A;  
Tripping Class: 10A; 2P, 3P; Auxiliary Contact: AC-  
15: Ue/Ie: 120V/6A, 240V/3A, 380V/1.9A, 480V/1.5A, 500V/1.4A, 600V/1.2A; DC-  
13: Ue/Ie: 125V/0.55A, 250V/0.27A

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.4-2010

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification (REF NO. CNCA-01C-011:2007).

Date of issue: May. 09, 2012 Date of expiry: May. 09, 2017

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Jan. 16, 2009

This certificate can be verified through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



President:

Wang Kejiao



**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

<http://www.cqc.com.cn>