



中国国家强制性产品认证证书

证书编号: 2012010307560105

委托人名称、地址

台安科技(无锡)有限公司
无锡国家高新技术产业开发区65-C号地块

生产者(制造商)名称、地址

台安科技(无锡)有限公司
无锡国家高新技术产业开发区65-C号地块

生产企业名称、地址

台安科技(无锡)有限公司
无锡国家高新技术产业开发区65-C号地块

产品名称和系列、规格、型号

漏电断路器

BR-32; Ue:AC230V(1P+N, 2P), 400V(3P, 3P+N); In:6A, 10A, 16A, 20A, 25A, 32A; 瞬时脱扣
类型:C型, D型; 电子式; I Δ n=0.03A/AC型, 电子式; Icn=Ics=6000A; I Δ m=2000A; 极
数:1P+N(N极常通), 2P, 3P, 3P+N(N极常通); 除1P+N, 3P+N外, 其他都适用于隔离;

产品标准和技术要求

GB 16917.1-2014, GB 16917.22-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02:2014的要求, 特发此证。

发证日期: 2015年10月27日 有效期至: 2017年08月13日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2012年08月13日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2012010307560105

NAME AND ADDRESS OF THE APPLICANT

TAIAN Technology (Wuxi) Co., Ltd.
Block 65-C, Wuxi National High-Tech Industry Development
Zone, Wuxi, Jiangsu Province, P. R. China

NAME AND ADDRESS OF THE MANUFACTURER

TAIAN Technology (Wuxi) Co., Ltd.
Block 65-C, Wuxi National High-Tech Industry Development
Zone, Wuxi, Jiangsu Province, P. R. China

NAME AND ADDRESS OF THE FACTORY

TAIAN Technology (Wuxi) Co., Ltd.
Block 65-C, Wuxi National High-Tech Industry Development
Zone, Wuxi, Jiangsu Province, P. R. China

NAME, MODEL AND SPECIFICATION

Residual Current Circuit-breaker

BR-32; Ue: AC230V (1P+N, 2P), 400V (3P, 3P+N); In: 6A, 10A, 16A, 20A, 25A, 32A; Type
C, D; Electronic Residual Current Tripping Unit; $I_{\Delta n} = 0.03A$ /Type
AC, Electronic; $I_{cn} = I_{cs} = 6000A$; $I_{\Delta m} = 2000A$; Poles: 1P+N (uninterrupted neutral
pole), 2P, 3P, 3P+N (uninterrupted neutral pole); Suitable for isolation except
1P+N, 3P+N;

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 16917.1-2014, GB 16917.22-2008

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification (REF
NO. CNCA-C03-02:2014).

Date of issue: Oct. 27, 2015 Date of expiry: Aug. 13, 2017

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

Date of original certification: Aug. 13, 2012

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

<http://www.cqc.com.cn>

