



中国国家强制性产品认证证书

证书编号: 2008010309312326

委托人名称、地址

台安科技(无锡)有限公司
无锡国家高新技术产业开发区65-C号地块

生产者(制造商)名称、地址

台安科技(无锡)有限公司
无锡国家高新技术产业开发区65-C号地块

生产企业名称、地址

台安科技(无锡)有限公司
无锡国家高新技术产业开发区65-C号地块

产品名称和系列、规格、型号

热过载继电器

RHU-5, RHN-5R, RHU-10, RHN-10R; Ue: AC690V; Ie: RHU-5, RHN-5R, RHU-10, RHN-10R:
0.10~0.16A, 0.16~0.25A, 0.25~0.4A, 0.35~0.50A, 0.45~0.63A, 0.55~0.8A,
0.75~1.0A, 0.9~1.3A, 1.1~1.6A, 1.4~2.0A, 1.8~2.5A, 2.3~3.2A, 2.9~4.0A,
3.5~4.8A, 4.5~6.3A, 5.5~7.5A, 7.2~10A, 9~12.5A; RHU-10, RHN-10R: 11.3~16A,
15~20A, 17.5~21.5A, 21~25A, 24.5~30A, 29~36A, 33~38A; 脱扣级别:10A; 极
数:2P, 3P; 辅助触头(本体):AC-15:
Ue/Ie: 120V/6A, 240V/3A, 380V/1.9A, 480V/1.5A, 500V/1.4A, 600V/1.2A; DC-13:
Ue/Ie: 125V/0.55A, 250V/0.27A; /

产品标准和技术要求

GB 14048.4-2010

上述产品符合强制性产品认证实施规则
CNCA-01C-011:2007的要求,特发此证。

发证日期: 2012年05月09日 有效期至: 2017年05月09日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书,证书首次颁发日期: 2008年12月16日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 0495360



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2008010309312326

NAME AND ADDRESS OF THE APPLICANT

TAIAN Technology (Wuxi) Co., Ltd.
Block 65-C, Wuxi National High-Technology Industry Development
Zone, Wuxi, Jiangsu Province, P. R. China

NAME AND ADDRESS OF THE MANUFACTURER

TAIAN Technology (Wuxi) Co., Ltd.
Block 65-C, Wuxi National High-Technology Industry Development
Zone, Wuxi, Jiangsu Province, P. R. China

NAME AND ADDRESS OF THE FACTORY

TAIAN Technology (Wuxi) Co., Ltd.
Block 65-C, Wuxi National High-Technology Industry Development
Zone, Wuxi, Jiangsu Province, P. R. China

NAME, MODEL AND SPECIFICATION

Thermal Overload Relay

RHU-5, RHN-5R, RHU-10, RHN-10R; U_e : AC690V; I_e : RHN-5, RHN-5R, RHU-10, RHN-10R:
0.10~0.16A, 0.16~0.25A, 0.25~0.4A, 0.35~0.50A, 0.45~0.63A, 0.55~0.8A,
0.75~1.0A, 0.9~1.3A, 1.1~1.6A, 1.4~2.0A, 1.8~2.5A, 2.3~3.2A, 2.9~4.0A,
3.5~4.8A, 4.5~6.3A, 5.5~7.5A, 7.2~10A, 9~12.5A; RHU-10, RHN-10R: 11.3~16A,
15~20A, 17.5~21.5A, 21~25A, 24.5~30A, 29~36A, 33~38A; Release
class: 10A; 2P, 3P; Auxiliary Contacts (of the relay): AC-15:
 U_e/I_e : 120V/6A, 240V/3A, 380V/1.9A, 480V/1.5A, 500V/1.4A, 600V/1.2A; DC-13:
 U_e/I_e : 125V/0.55A, 250V/0.27A;

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.4-2010

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification (REF NO. CNCA-01C-011:2007).

Date of issue: May.09, 2012 Date of expiry: May.09, 2017

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Dec.16, 2008

This certificate can be verified through CNCA's website: www.cqcc.com.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>