



中国国家强制性产品认证证书

证书编号: 2014010307732093

委托人名称、地址

台安科技(无锡)有限公司
江苏省无锡国家高新技术产业开发区65-C号地块

生产者(制造商)名称、地址

台安科技(无锡)有限公司
江苏省无锡国家高新技术产业开发区65-C号地块

生产企业名称、地址

台安科技(无锡)有限公司
江苏省无锡国家高新技术产业开发区65-C号地块

产品名称和系列、规格、型号

电动机保护断路器

TMS-63S; 详见参数附件

产品标准和技术要求

GB 14048.2-2008, GB 14048.4-2010

上述产品符合强制性产品认证实施规则
CNCA-01C-011: 2007的要求, 特发此证。

发证日期: 2014年10月31日

有效期至: 2019年10月31日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 0973888



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2014010307732093

NAME AND ADDRESS OF THE APPLICANT

TAIAN Technology (Wuxi) Co., Ltd.
Block 65-C, Wuxi National High-Technology Industry Development Zone, Wuxi,
Jiangsu Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

TAIAN Technology (Wuxi) Co., Ltd.
Block 65-C, Wuxi National High-Technology Industry Development Zone, Wuxi,
Jiangsu Province, P.R.China

NAME AND ADDRESS OF THE FACTORY

TAIAN Technology (Wuxi) Co., Ltd.
Block 65-C, Wuxi National High-Technology Industry Development Zone, Wuxi,
Jiangsu Province, P.R.China

NAME, MODEL AND SPECIFICATION

Motor-protective Circuit-breaker

TMS-63S; See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.2-2008, GB 14048.4-2010

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification (REF NO. CNCA-01C-011:2007).

Date of issue: Oct. 31, 2014 Date of expiry: Oct. 31, 2019

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

<http://www.cqc.com.cn>



Q 0973888



中国国家强制性产品认证证书

附录:

第 1 页 共 2 页

证书编号: 2014010307732093

纸号: 973888

TMS-63S;

Ui:1000V;

Ue:AC220/240V, AC380/415V, AC600/690V;

In:10A, 13A, 16A, 20A, 26A, 32A, 40A, 50A, 63A;

过电流脱扣器类型:热磁式;

Ics/ Icu:

AC220/240V:100kA/100kA(10A-16A), 38kA/50kA(20-63A);

AC380/415V:100kA/100kA(10A), 38kA/50kA(13A), 19kA/25kA(16-63A);

AC600/690V:3kA/4kA;

脱扣级别:10;

使用类别:A;

3P;

配用的辅助触头(1NO+1NC,2NO,2NC):

Ith:10A;

Ue/Ie:

AC-15:AC120V/6A, 240V/3A, 380V/1.9A, 480V/1.5A, 500V/1.4A, 600V/1.2A;

DC-13:DC125V/0.55A, 250V/0.27A

注: 此附录与证书同时使用时有效。



主 任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 2 页 共 2 页

证书编号: 2014010307732093

纸号: 973888

型号的解释:

TMS-63 S-□□□

(1) (2) (3) (4)

(1)产品代号:

TMS: 电动机保护断路器

(2)框架电流

(3)分断能力: S(标准分断能力)

(4)电流标称值

010: 6.3-10A

032: 22-32A

013: 9-13A

040: 28-40A

016: 11-16A

050: 35-50A

020: 14-20A

063: 45-63A

026: 18-26A

注: 此附录与证书同时使用时有效。



主 任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>

