



# 中国国家强制性产品认证证书

证书编号: 2011010309479594

委托人名称、地址

台安科技(无锡)有限公司  
江苏省无锡国家高新技术产业开发区65-C号地块

生产者(制造商)名称、地址

台安科技(无锡)有限公司  
江苏省无锡国家高新技术产业开发区65-C号地块

生产企业名称、地址

台安科技(无锡)有限公司  
江苏省无锡国家高新技术产业开发区65-C号地块

产品名称和系列、规格、型号

热过载继电器

RHN-180; Ue:AC690V;Ie:65~95A, 85~125A, 110~160A, 125~185A;脱扣级别:10;3P;配用的辅助触头:AC-15:Ue/Ie:120V/6A, 125V/3A, 380V/1.9A, 480V/1.5A, 500V/1.4A, 600V/1.2A;DC-13:Ue/Ie:125V/0.55A, 250V/0.27A;型号详见附录

产品标准和技术要求

GB 14048.4-2010

上述产品符合强制性产品认证实施规则  
CNCA-C03-02:2014的要求,特发此证。

发证日期: 2016年03月31日

有效期至: 2021年03月31日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书,证书首次颁发日期: 2011年06月20日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1389352





# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2011010309479594

## NAME AND ADDRESS OF THE APPLICANT

TAIAN Technology (Wuxi) Co., Ltd.  
Block 65-C, Wuxi National High-Technology Industry Development  
Zone, Wuxi, Jiangsu Province, P. R. China

## NAME AND ADDRESS OF THE MANUFACTURER

TAIAN Technology (Wuxi) Co., Ltd.  
Block 65-C, Wuxi National High-Technology Industry Development  
Zone, Wuxi, Jiangsu Province, P. R. China

## NAME AND ADDRESS OF THE FACTORY

TAIAN Technology (Wuxi) Co., Ltd.  
Block 65-C, Wuxi National High-Technology Industry Development  
Zone, Wuxi, Jiangsu Province, P. R. China

## NAME, MODEL AND SPECIFICATION

Thermal Overload Relay

RHN-180; Ue:AC690V;Ie:65~95A, 85~125A, 110~160A, 125~185A;Tripping  
Class:10;3P;Attached Auxiliary Contacts:AC-  
15:Ue/Ie:120V/6A, 125V/3A, 380V/1.9A, 480V/1.5A, 500V/1.4A, 600V/1.2A;DC-  
13:Ue/Ie:125V/0.55A, 250V/0.27A;See the Appendix

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.4-2010

This is to certify that the above mentioned products have met the  
requirements of implementation rules for compulsory certification(REF  
NO. CNCA-C03-02:2014).

Date of issue: Mar.31,2016      Date of expiry: Mar.31,2021

Validity of this certificate is subject to positive result of the regular  
follow up inspection by issuing certification body until the expiry date.

Date of original certification: Jun.20,2011

This certificate can be verified through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



President:

Wang Kejiao

**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 1389352





# 中国国家强制性产品认证证书

附录:

第 1 页 共 1 页

证书编号: 2011010309479594

纸号: 1389352

型号的解释:

RHN- 180 / □ □ □ □  
(1) (2) (3) (4) (5) (6)

(1) RHN: 热过载继电器

(2) 180 系列

(3) 负载侧接线固定方式:

空白: 线夹式

L: LUG 式

(4) 标称电流:

以旋钮刻度最大额定电流表示

95, 125, 160, 185

(5) 构造别:

A 表示: 过载保护+缺相保护

K 表示: 过载保护

(6) 安装方式:

1: 搭配 CN-100/125

2: 搭配 CN-150

3: 搭配 CN-180

4: 搭配 CN-220/300

P: 独立安装型

注: 此附录与证书同时使用时有效。



主 任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

